



- WARNINGS:**
- Do not use Surface Mount Brackets.
 - This Frame is **ONLY** to be used on a flat non-sloped ceiling.
 - Heater Body must face straight down and **be flush with the finished ceiling.**
 - Frame and Heater cannot be installed on a pitched angle.
 - Accessible Junction Box must be installed outside of sealed drywall pocket.
 - Must use $\frac{5}{8}$ " type "X" drywall.
 - Must use supplied 4 foot Hi-Temp Fixture Whip and Hi-Temp Ceramic Wire Nuts.
 - **Please contact factory for longer length Hi-Temp Fixture Whips available for purchase.**
 - Discard Surface Mounting Brackets provided with Heater and use "L" Brackets.
 - Use Licensed Electrician **ONLY.**

- NOTES:**
- Heater suspends (Gravity) by resting on adjustable "L" Brackets in flush mount fixture.
 - Mounting holes on Surface Flange to be determined and drilled by Contractor/Installer.
 - Coil excess flex into heater cavity.

After 4 hours of continuous use, a 15 minute cool down period is recommended for maximum heater longevity. See controls brochure for timer options.

| | | |
|---|---------|--|
| INFRA TECH www.infratech-usa.com | | 15700 S. Figueroa St. Gardena, California 90248 Phone: (310) 354-1250 Fax: (310) 523-3674 |
| ITEM #: | 18-2295 | MATERIAL: 304 S.S. #4 FINISH |
| DESCRIPTION: W-33 FLUSH MOUNT FRAME (FOR USE WITH 33" HEATERS) | | |
| NOTES: SUPPLIED w/ HI-TEMP FIXTURE WHIP | | |
| DATE: | SCALE: | DRAWN BY: |
| Dec. 16, 2019 | N/A | CL |